


FIRST FLOOR LIGHTING PLAN
SCALE: 1/8" = 1'-0"



ELECTRICAL SPECIFIC NOTES:

- 1 SEAL ALL PENETRATIONS THROUGH CEILING, AND WALLS, BOTH OUTSIDE AND INSIDE WALK-IN FREEZER/COOLER WITH DOW CORNING #999A SILICONE GLAZING SEALANT OR PRIOR APPROVED EQUAL.

ELECTRICAL MISCELLANEOUS NOTES:

- A. THE MAJORITY OF THE EXISTING WALLS ON THIS PROJECT ARE BEING FURRED OUT TO ACCOMODATE NEW CONDUIT, WIRING, AND ELECTRICAL DEVICES. WHERE EXISTING WALLS ARE NOT BEING FURRED OUT THE ELECTRICAL CONTRACTOR SHALL TRY TO MINIMIZE THE SURFACE RACEWAY BY FISHING CONDUCTORS THROUGH WALLS AND CEILINGS AS MUCH AS POSSIBLE. COORDINATE SURFACE RACEWAY TYPE, QUANTITY, AND LOCATION WITH THE GENERAL CONTRACTOR AND ARCHITECT PRIOR TO INSTALLATION.
- B. ALL EMERGENCY FIXTURES (SHADED) SHALL BE PROVIDED WITH AN UNSWITCHED HOT AS WELL AS A SWITCHED HOT. THE EMERGENCY DRIVER SHALL OPERATE WHEN POWER IS LOST FOR THE CIRCUIT.
- C. ALL EMERGENCY EXIT SIGNS (FIXTURE TYPE X) SHALL BE PROVIDED WITH AN UNSWITCHED HOT AND ARE TO BE WIRED AS NORMALLY ON. THE EMERGENCY DRIVER SHALL OPERATE WHEN POWER IS LOST FOR THE CIRCUIT.
- D. FIXTURE TYPES EM AND WE SHALL BE PROVIDED WITH AN UNSWITCHED HOT AND ARE TO BE WIRED AS NORMALLY OFF AND OPERATE WHEN POWER IS LOST FOR THE CIRCUIT.
- E. LOWERCASE LETTER NEXT TO LIGHT FIXTURES (WHERE SHOWN) INDICATE THE SWITCHING CONFIGURATION. A MATCHING LETTER IS SHOWN NEXT TO THE CORRESPONDING LIGHT SWITCH IN THAT SPACE.
- F. CONTRACTOR TO AIM LED HEADS OF FIXTURE TYPE EM FOR PATH TO EGRESS.